

Checklist mobiele brandblustoestellen volgens de NORM NBN S21-050 (2002)

Kwartier: KKE                      Blok: 6D                      Verdiep: -1 - 0 - +1 - +2  
 Plaats: CCI

Kwartier	Locatie Blok/plaats	Verdiep	Type blustoestel	Inhoud Kg	Nr. Blustoestel	hangt/staat op de voorziene plaats*	Toegankelijk*	Duidelijk zichtbaar*	leesbare en juiste gebruiksaanwijzing*	Zichtbaar niet beschadigd*	Naald drukmeter in groene zone*	verzegeling voorhanden en niet beschadigd*	Signalisatie voorhanden	Jaarlijkse controle is gebeurd	Verslag is beschikbaar
KKE	Blok 6D	-1	Poeder	6	1/P6/4173	OK	OK	OK	OK	OK	NVT	OK	NOK	OK	OK
KKE	Blok 6D	-1	Poeder	6	13/P6/89704	OK	OK	OK	OK	OK	NVT	OK	OK	OK	OK
KKE	Blok 6D	-1	Poeder	6	1/P6/4169	OK	OK	OK	OK	OK	NVT	OK	OK	OK	OK
KKE	Blok 6D	-1	CO2	5	11/C5/32173	OK	OK	OK	OK	OK	NVT	OK	OK	OK	OK
KKE	Blok 6D	-1	CO2	5	09/C5/57146	OK	OK	OK	OK	OK	NVT	OK	NOK	OK	OK
KKE	Blok 6D	0	Poeder	6	13/P6/89627	OK	OK	OK	OK	OK	NVT	OK	NOK	OK	OK
KKE	Blok 6D	0	Poeder	6	1/P6/1268	OK	OK	OK	OK	OK	NVT	OK	OK	OK	OK
KKE	Blok 6D	0	Poeder	6	1/P6/5607	OK	OK	OK	OK	OK	NVT	OK	OK	OK	OK
KKE	Blok 6D	0	Poeder	6	1/P6/94213	OK	OK	OK	OK	OK	NVT	OK	OK	OK	OK
KKE	Blok 6D	1	Poeder	6	1/P6/5492	OK	OK	OK	OK	OK	NVT	OK	OK	OK	OK
KKE	Blok 6D	1	Poeder	6	1/P6/5455	OK	OK	OK	OK	OK	NVT	OK	OK	OK	OK
KKE	Blok 6D	1	CO2	5	13/C5/06829	OK	OK	OK	OK	OK	NVT	OK	OK	OK	OK
KKE	Blok 6D	1	CO2	5	13/C5/41673	OK	OK	NOK	OK	OK	NVT	OK	NOK	OK	OK
KKE	Blok 6D	2	Poeder	6	1/P6/1254	OK	OK	OK	OK	OK	NVT	OK	OK	OK	OK
KKE	Blok 6D	2	Poeder	6	1/P6/690	OK	OK	OK	OK	OK	NVT	OK	NOK	OK	OK
KKE	Blok 6D	2	Poeder	6	09/P6/03375	OK	OK	OK	OK	OK	NVT	OK	NOK	OK	OK
KKE	Blok 6D	2	CO2	5	13/C5/06861	OK	OK	OK	OK	OK	NVT	OK	OK	OK	OK

Datum van de controle: 06 Maars 2019.

Uitvoerder

Naam: VAN PUYENBROECK  
 Graad: CAPORAL CHEF  
 Handtekening:



Checklist mobiele brandblustoestellen volgens de NORM NBN S21-050 (2002)

Kwartier: KKE Blok: 6D Verdiep: -1 - 0 - +1 - +2  
 Plaats: CCI

Kwartier	Locatie Blok/plaats	Verdiep	Type blustoestel	Inhoud Kg	Nr. Blustoestel	hangt/staat op de voorziene plaats*	Toegankelijk*	Duidelijk zichtbaar*	leesbare en juiste gebruiksaanwijzing*	Zichtbaar niet beschadigd*	Naald drukmeter in groene zone*	verzegeling voorhanden en niet beschadigd*	Signalisatie voorhanden	Jaarlijkse controle is gebeurd	Verslag is beschikbaar
KKE	Blok 6D	-1	Poeder	6	1/P6/4173	OK	OK	OK	OK	OK	NVT	OK	NOK	OK	OK
KKE	Blok 6D	-1	Poeder	6	13/P6/89704	OK	OK	OK	OK	OK	NVT	OK	OK	OK	OK
KKE	Blok 6D	-1	Poeder	6	1/P6/4169	OK	OK	OK	OK	OK	NVT	OK	OK	OK	OK
KKE	Blok 6D	-1	CO2	5	11/C5/32173	OK	OK	OK	OK	OK	NVT	OK	OK	OK	OK
KKE	Blok 6D	-1	CO2	5	09/C5/57146	OK	OK	OK	OK	OK	NVT	OK	NOK	OK	OK
KKE	Blok 6D	0	Poeder	6	13/P6/89627	OK	OK	OK	OK	OK	NVT	OK	NOK	OK	OK
KKE	Blok 6D	0	Poeder	6	1/P6/1268	OK	OK	OK	OK	OK	NVT	OK	OK	OK	OK
KKE	Blok 6D	0	Poeder	6	1/P6/5607	OK	OK	OK	OK	OK	NVT	OK	OK	OK	OK
KKE	Blok 6D	0	Poeder	6	1/P6/94213	OK	OK	OK	OK	OK	NVT	OK	OK	OK	OK
KKE	Blok 6D	1	Poeder	6	1/P6/5492	OK	OK	OK	OK	OK	NVT	OK	OK	OK	OK
KKE	Blok 6D	1	Poeder	6	1/P6/5455	OK	OK	OK	OK	OK	NVT	OK	OK	OK	OK
KKE	Blok 6D	1	CO2	5	13/C5/06829	OK	OK	OK	OK	OK	NVT	OK	OK	OK	OK
KKE	Blok 6D	1	CO2	5	13/C5/41673	OK	OK	NOK	OK	OK	NVT	OK	NOK	OK	OK
KKE	Blok 6D	2	Poeder	6	1/P6/1254	OK	OK	OK	OK	OK	NVT	OK	OK	OK	OK
KKE	Blok 6D	2	Poeder	6	1/P6/690	OK	OK	OK	OK	OK	NVT	OK	NOK	OK	OK
KKE	Blok 6D	2	Poeder	6	09/P6/03375	OK	OK	OK	OK	OK	NVT	OK	NOK	OK	OK
KKE	Blok 6D	2	CO2	5	13/C5/06861	OK	OK	OK	OK	OK	NVT	OK	OK	OK	OK

Datum van de controle: 06 Mars 2019.

Uitvoerder  
 Naam: VAN PUYENBROECK  
 Graad: CAPORAL CHEF  
 Handtekening: