

Checklist Muurhaspel volgens de NORM EN 671-1 en 671-3 = controle

Kwartier: KKE

Blok: 1.GELIJKVLOERS-DGBudFin

Kwartier	Locatie	Nr Brandhaspel	Type	Soort	Haspel aanwezig	Slang aanwezig	Lans aanwezig	Drukmeter aanwezig	Systeem toegankelijk	Algemene staat	Technisch probleem	Onder druk	Pictogram	Markering/gebruiksaanwijzing
KKE	1-0 GANG	21006C - 10.25	19/20 mondstuk 6mm	vast	OK	OK	OK	NV	OK	Algemene staat OK	OK	OK	OK	OK
					Kast in orde	OK	OK	OK	OK	OK	OK	OK	OK	OK
					Haspel in orde	OK	OK	OK	OK	OK	OK	OK	OK	OK
					Bedieningshendel in orde	OK	OK	OK	OK	OK	OK	OK	OK	OK
					Haspelsteun in orde	OK	OK	OK	OK	OK	OK	OK	OK	OK
					half vormvaste slang in orde	OK	OK	OK	OK	OK	OK	OK	OK	OK
					Lans in orde	OK	OK	OK	OK	OK	OK	OK	OK	OK
					Kappen, onzuiverheden	OK	OK	OK	OK	OK	OK	OK	OK	OK
					Corrosie	OK	OK	OK	OK	OK	OK	OK	OK	OK
					Corrosie leidingen	OK	OK	OK	OK	OK	OK	OK	OK	OK
					Corrosie elementen	OK	OK	OK	OK	OK	OK	OK	OK	OK
					Technisch probleem	OK	OK	OK	OK	OK	OK	OK	OK	OK
					Deur	OK	OK	OK	OK	OK	OK	OK	OK	OK
					Haspel	OK	OK	OK	OK	OK	OK	OK	OK	OK
					Haspelsteun	OK	OK	OK	OK	OK	OK	OK	OK	OK
					Drukmeter	OK	OK	OK	OK	OK	OK	OK	OK	OK
					Slangengeleider	OK	OK	OK	OK	OK	OK	OK	OK	OK
					Slang	OK	OK	OK	OK	OK	OK	OK	OK	OK
					Toever water	OK	OK	OK	OK	OK	OK	OK	OK	OK
					Druk	OK	OK	OK	OK	OK	OK	OK	OK	OK
					Technisch probleem	OK	OK	OK	OK	OK	OK	OK	OK	OK
					Bedieningshendel	OK	OK	OK	OK	OK	OK	OK	OK	OK
					Lans 3 standen	OK	OK	OK	OK	OK	OK	OK	OK	OK
					Lek	OK	OK	OK	OK	OK	OK	OK	OK	OK

Datum van de controle:

09/01/2020

Uitvoerder

Naam: Keppens A,

Graad: Adjt

Handtekening:


Checklist mobiele brandblustoestellen volgens de NORM NBN S21-050 (2002)

Kwartier: KKE Blok: 1C Verdiep: 0
 Plaats: Gang

Kwartier	Locatie Blok/plaats	Verdiep	Soort blustoesel	Inhoud	Nr. Blustoestel	hangt/stat op de voorziene plaats*	Toegankelijk*	Duidelijk zichtbaar*	leesbare en juiste gebruiksaanwijzing*	Zichtbaar niet beschadigd*	Naald drukmeter in groene zone*	verzegeling voorhanden en niet beschadigd*	Signalisatie voorhanden	jaarlijkse controle is gebeurd	Datum jaarlijkse controle	Verlag is beschikbaar
KKE	1C0-43	0	Poeder	6 Kg	13P689975	OK	OK	OK	OK	OK	NVT	OK	OK	OK	nov/19	NOK
KKE	1C0-42	0	CO2	5 Kg	11C599997	OK	OK	OK	OK	OK	NVT	OK	OK	OK	nov/19	NOK
KKE	1C0-39	0	Poeder	6 Kg	13P689934	OK	OK	OK	OK	OK	NVT	OK	OK	OK	nov/19	NOK
KKE	1C0-37	0	CO2	5 Kg	11C502902	OK	OK	OK	OK	OK	NVT	OK	OK	OK	nov/19	NOK
KKE	1C0-34	0	Poeder	6 Kg	13P6895681	OK	OK	OK	OK	OK	NVT	OK	OK	OK	nov/19	NOK

Datum van de controle: 09/01/2020

Uitvoerder
 Naam: Keppens A,
 Graad: Adjt
 Handtekening:



Checklist mobiele brandblustoestellen volgens de NORM NBN S21-050 (2002)

Kwartier: KKE Blok: 4C Verdiep: 0
Plaats: 0

Kwartier	Locatie Blok/plaats	Verdiep	Type blustoestel	Inhoud	Nr. Blustoestel	hangt/staat op de voorziene plaats*	Toegankelijk*	Duidelijk zichtbaar*	leesbare en juiste gebruiksaanwijzing*	Zichtbaar niet beschadigd*	Naald drukmeter in groene zone*	verzegeling voorhanden en niet beschadigd*	Signalisatie voorhanden	jaarlijkse controle is gebeurd	Datum jaarlijkse controle	Verstap is beschikbaar
KKE	4C0-85	0	Poeder	6 Kg	11P6 94331	OK	OK	OK	OK	OK	NVT	OK	NOK	OK	nov/19	NOK
KKE	4C0-98	0	CO2	5 Kg	13C5 72627	OK	OK	OK	OK	OK	NVT	OK	OK	OK	nov/19	NOK
KKE	4C0-91	0	Poeder	6 Kg	11P6 94252	OK	OK	OK	OK	OK	NVT	OK	OK	OK	nov/19	NOK
KKE	4C0-54	0	CO2	5 Kg	13C531661	OK	OK	OK	OK	OK	NVT	OK	OK	OK	nov/19	NOK
KKE	4C0-71	0	Poeder	6 Kg	1P6/4116	OK	OK	OK	OK	OK	NVT	OK	OK	OK	nov/19	NOK
KKE	4C0-30	0	Poeder	6 Kg	1P6/4124	OK	OK	OK	OK	OK	NVT	OK	OK	OK	nov/19	NOK
KKE	4C0-75	0	CO2	5 Kg	15C5 91065	OK	OK	OK	OK	OK	NVT	OK	OK	OK	nov/19	NOK
KKE	4C0-31	0	Poeder	6 Kg	11P6 64486	OK	OK	OK	OK	OK	NVT	OK	OK	OK	nov/19	NOK
KKE	4C0-129	0	Poeder	6 Kg	1P6/4162	OK	OK	OK	OK	OK	NVT	OK	OK	OK	nov/19	NOK
KKE	4C0-54	0	Poeder	6 Kg	1P6/4123	OK	OK	OK	OK	OK	NVT	OK	NOK	OK	nov/19	NOK
KKE	4C0-54	0	Poeder	50 Kg	10P50/60506	OK	OK	OK	OK	OK	NVT	OK	NOK	NOK	nov/19	NOK
KKE	4C0-54	0	Poeder	12 Kg	11P12/24389	OK	OK	OK	OK	OK	NVT	OK	NOK	NOK	nov/19	NOK

Datum van de controle: 09/01/2020

Naam: Keppens A,
Graad: Adjt
Handtekening:



Uitvoerder

Checklist mobiele brandblustoestellen volgens de NORM NBN S21-050 (2002)

Kwartier: KKE Blok: 4C Verdiep: 1
Plaats:

Kwartier	Locatie Blok/plaats	Verdiep	Type blustoestel	Inhoud	Nr. Blustoestel	hangt/staat op de voorziene plaats*	Toegankelijk*	Duidelijk zichtbaar*	leesbare en juiste gebruiksaanwijzing*	Zichtbaar niet beschadigd*	Naald drukmeter in groene zone*	verzegeling voorhanden en niet beschadigd*	Signalisatie voorhanden	jaarlijkse controle is gebeurd	Datum jaarlijkse controle	Verslag is beschikbaar
KKE	4C1-84	1	Poeder	6 Kg	1P6/4140	OK	OK	OK	OK	OK	NVT	OK	OK	OK	nov/19	NOK
KKE	4C1-72	1	CO2	5 Kg	13C5 39149	OK	OK	OK	OK	OK	NVT	OK	OK	OK	nov/19	NOK
KKE	4C1-87	1	Poeder	6 Kg	1P6/4148	OK	OK	OK	OK	OK	NVT	OK	OK	OK	nov/19	NOK
KKE	4C1-91	1	Poeder	6 Kg	1P6/4163	OK	OK	OK	OK	OK	NVT	OK	OK	OK	nov/19	NOK
KKE	4C1-54	1	Poeder	6 Kg	1P6/4165	OK	OK	OK	OK	OK	NVT	OK	OK	OK	nov/19	NOK
KKE	4C1-63	1	Poeder	6 Kg	1P6/4154	OK	OK	OK	OK	OK	NVT	OK	OK	OK	nov/19	NOK
KKE	4C1-60	1	Poeder	6 Kg	11P6 39185	OK	OK	OK	OK	OK	NVT	OK	OK	OK	nov/19	NOK
KKE	4C1-32A	1	CO2	5 Kg	14C5 77245	OK	OK	OK	OK	OK	NVT	OK	OK	OK	nov/19	NOK
KKE	4C1-38	1	Poeder	6 Kg	11P6 40445	OK	OK	OK	OK	OK	NVT	OK	OK	OK	nov/19	NOK
KKE	4C1-65	1	CO2	5 Kg	13C5 06825	OK	OK	OK	OK	OK	NVT	OK	OK	OK	nov/19	NOK
KKE	4C1-52	1	CO2	5 Kg	13C5 32715	OK	OK	OK	OK	OK	NVT	OK	OK	OK	nov/19	NOK
KKE	4CD1-4	1	CO2	5 Kg	13C5 21201	OK	OK	OK	OK	OK	NVT	OK	OK	OK	nov/19	NOK
KKE	4CD1-11	1	Poeder	6 Kg	1P6 39185	OK	OK	OK	OK	OK	NVT	OK	OK	OK	nov/19	NOK

Datum van de controle: 09/01/2020

Uitvoerder
 Naam: Keppens A.
 Graad: Adjt
 Handtekening:



Checklist mobiele brandblustoestellen volgens de NORM NBN S21-050 (2002)

Kwartier: KKE Blok: 4C Verdiep: 2
Plaats:

Kwartier	Locatie Blok/plaats	Verdiep	Type blustoestel	Inhoud	Nr. Blustoestel	hangt/staat op de voorziene plaats*	Toegankelijk*	Duidelijk zichtbaar*	leesbare en juiste gebruiksaanwijzing*	Zichtbaar niet beschadigd*	Naal drukmeter in groene zone*	vergeging vorhanden en niet beschadigd*	Signalisatie voorhanden	jaarlijkse controle is gebeurd	Datum jaarlijkse controle	Verlag is beschikbaar
KKE	4C2-60	2	Poeder	6 Kg	1P6/4157	OK	OK	OK	OK	OK	NVT	OK	OK	OK	nov/19	NOK
KKE	4C2-46	2	CO2	5 Kg	14C5 77331	OK	OK	OK	OK	OK	NVT	OK	OK	OK	nov/19	NOK
KKE	4C2-44	2	Poeder	6 Kg	1P6/4151	OK	OK	OK	OK	OK	NVT	OK	OK	OK	nov/19	NOK
KKE	4C2-37	2	Poeder	6 Kg	1P6/4144	OK	OK	OK	OK	OK	NVT	OK	OK	OK	nov/19	NOK
KKE	4C2-35	2	CO2	5 Kg	11C5 02865	OK	OK	OK	OK	OK	NVT	OK	OK	OK	nov/19	NOK
KKE	4C2-31	2	Poeder	6 Kg	1P6 4149	OK	OK	OK	OK	OK	NVT	OK	OK	OK	nov/19	NOK
KKE	4C2-130	2	Poeder	6 Kg	11P6 93983	OK	OK	OK	OK	OK	NVT	OK	OK	OK	nov/19	NOK
KKE	4C2-89	2	CO2	5 Kg	14C5 77320	OK	OK	OK	OK	OK	NVT	OK	OK	OK	nov/19	NOK
KKE	4C2-93	2	Poeder	6 Kg	1P6/4146	OK	OK	OK	OK	OK	NVT	OK	OK	OK	nov/19	NOK
KKE	4C2-97	2	Poeder	6 Kg	11P6/94225	OK	OK	OK	OK	OK	NVT	OK	OK	OK	nov/19	NOK
KKE	4C2-120	2	CO2	5 Kg	13C5 28384	OK	OK	OK	OK	OK	NVT	OK	OK	OK	nov/19	NOK
KKE	4C2-104	2	Poeder	6 Kg	1P6/4251	OK	OK	OK	OK	OK	NVT	OK	OK	OK	nov/19	NOK
KKE	4CD2-04	2	Poeder	6 Kg	1P6 4147	OK	OK	OK	OK	OK	NVT	OK	OK	OK	nov/19	NOK
KKE	4CD2-05	2	CO2	5 Kg	13C5 62207	OK	OK	OK	OK	OK	NVT	OK	OK	OK	nov/19	NOK

Datum van de controle: 09/01/2020

Uitvoerder
 Naam: Keppens A,
 Graad: Adjt
 Handtekening:

